



Providing quality water, power and service at a competitive price that our customers value

May 21, 2020

Sherrie Ringstad
City of Mill creek
15728 Main Street
Mill Creek, WA 98012

Dear Ms. Ringstad.:

Reference No.: PL2019 0014 7C's Swim School

District DR Number: 20-109

The District presently has enough electric system capacity to serve the proposed development. However, the existing District facilities in the local area may require upgrading. The developer is required to supply the District with suitable locations/easements on all parcels where electrical facilities must be installed to serve the proposed development. It is unlikely that easements will be granted on District-owned property, or consents granted within District transmission line corridors.

Existing PUD facilities may need relocations or modifications at the developer's expense. Three-phase power will have to be brought to the site from Bothell-Everett Highway, and primary line extension will be required. Any relocation, alteration or removal of District facilities to accommodate this project shall be at the expense of the project developer and must be coordinated with the PUD in advance of final design. Please include any utility work in the scope of all land-use permits.

Cost of any work, new or upgrade, to existing facilities that is required to connect this proposed development to the District electric system shall be in accordance with the applicable District policy.


Please contact the District prior to design of the proposed project. For information about specific electric service requirements, please call the District's South County office at 425-670-3200 to contact a Customer Engineer.

Sincerely,

Mary Wicklund for

Gordon Hayslip, Interim Senior Manager
Transmission & Distribution System
Operations & Engineering

Cc: Trevor Gaskin / trevor@coast-group.com
Tom Hovde – E2



Providing quality water, power and service at a competitive price that our customers value