

TECHNICAL MEMORANDUM

2707 Colby Avenue, Suite 900, Everett, WA 98201 | P 425.252.7700

To: Matthew Feeley PE, Supervising Engineer, City of Mill Creek

From: Brian Caferro, PE, Perteet

Date: May 06, 2020

Re: 7C's Swim School – Review Comments

The purpose of this memorandum is to provide formal notification that I have reviewed the following 7C's Swim School development application documents as they relate to drainage design, grading design and Temporary Erosion and Sediment Control design:

- Engineering Design Drawings (Dated 04/30/2020)
- Stormwater Management Report (Dated 04/30/2020)
- Construction Stormwater Pollution Prevention Plan (04/30/20)
- Geotechnical Engineering Report (12/13/2018)
- Geotechnical Report Addendum (Dated 01/08/2020)

Based on my review, I have determined that these documents meet the requirements of the City Municipal Codes and the regulations of the Washington State Department of Ecology, with the exception of one minor comment as indicated below.

Plans**Sheet C3.7 (Lift Station Details)**

- The plan view detail calls for a 48-inch diameter wet well and valve vault but the Bill of Materials table, as well as the drainage report calculations, calls out 72-inch diameter for both. Correct this discrepancy in the plans.

END MEMO